CERT.jpg

Certificate Of Inspection

HARCON SERVICES LIMITED

108, Manchester Rd
Carrington
Manchester
M31 4BD

TEL: 0161 777 4230
FAX: 0161 777 4231

Certificate Number	Date Of Inspection	Re-inspection Date

Project Title	Type Of System (i.e. Ariana, Latchway or other, please specify)	Description Of Works
	Ariana System	*Annual Inspection Of Fall Arrest Systems to the roof*

Customer Address	Site Address (if different)

Test Type / Description	Re-inspection Notes
Inspection of Ariana Safety Cable System. Inspected systems for wear and tear and checked all fittings for tightness and tension settings. Checked traveller for smooth operation along the system.	**Personal protective equipment against falls from height - General requirements** *At least once every 12 months [illegible] device identified in accordance [illegible] manufacturer's instructions [illegible] competent person or specialist*
Recommendations (if any)	**Results**
	Archive [illegible] Certificate

! WARNING !

System can fail if damaged, missured, out of date or as a result [illegible] proper use or Maintenance

Test Type/Description (PPE only)	PPE Notes
	Please read PPE notes above *The full body harness and associated equipment must be inspected by a competent person other than the user at least annually. Before each use, the operative should visually inspect to ensure the items are in serviceable condition. Check for worn or damaged parts. Ensure all components are complete and secure and are not distorted, or have any sharp edges or signs of corrosion. Ensure karabiners etc work properly and inspect rope/webbing/wire rope for wear, cuts, burns, frayed edges, breaks or other damage. Do not use if inspection reveals an unsafe condition*

Product Inspected	Date	Serial Number

Recommendations (if any)	Results

! WARNING !
Ensure you understand all instructions before using the system. A fall could result in serious injury or death.
Do not use unless properly trained

Inspected By	Witnessed By	Max Number Of Users
		Two

Harcon Services Limited certify that the system (s) described are fit for use, subject to recommendation.

evolution horizontal lifeline SALA

5/1/2008
Page 1

PROTECTA

SAMPLE